

ANNUAL SYSTEM OPERATION & MAINTENANCE CHECKLIST

School Name _____ Field Name _____

Date of Inspection _____ Voltage/Phase _____ Date Installed _____

Type of Pole _____ Type/# of Luminaires _____

Inspected By _____ Title: _____ Contact Number _____

Needs
OK Repair N/A Notes

WARNING! Turn off electricity at power source and at safety disconnect on poles

Lighting Performance Testing					Notes
Check with the AD and Staff to see if there are any concerns regarding field (pole, electrical or lighting)					
Average maintained footcandles meet guidelines					
Uniformities meet guidelines					
Service Entrance, Poles, and Distribution Boxes					
Warning Stickers, wiring diagrams, circuit labels should be posted and legible *					
Snap all breakers on and off several times to ensure firm contact. Utilizing breakers for on/off control is not recommended due to reducing the effectiveness of the devices for overcurrent protection. Also, risk of arc flash is increased as breakers age and appropriate precautions should to taken. See NEC 110.16-A Arc Flash *					
Check fuses for continuity					
Insulation around wiring should show no signs of deterioration *					
Wiring should show no heat discoloration *					
Signs of wear should be replaced on taped connections *					
Bare wires and exposed connections should be wrapped with insulated covering *					
Are the panels appropriately locked or access minimized from the public *					
Check all grounding connections at service entrance and at poles. The grounding systems are required to comply with NFPA 70. *					
1. Is a ground rod present?					
2. Are the bolted connections in good condition?					
3. Are the grounding components from acceptable materials and are they sized properly?					
4. Is the resistance level satisfactory? This can be verified by measuring resistance to ground. Which for a single rod it should be 25 ohms or less. If it's higher, then a second ground rod shall be added. There is no requirement for minimum resistance value, if two grounds are installed.					
Pole Structures					
Wood poles checked for leaning and resulting misalignment of luminaires					
Wood poles checked for twisting and resulting misalignment of luminaires					
Wood poles checked for decay. Just below ground level, woodpecker holes etc. *					
Steel anchor bolt poles checked for signs of corrosion *					
Steel anchor bolt poles checked for proper drainage in grout at base					
Direct burial steel poles checked for proper mastic covering above/below grade at base to ensure no corrosion or pitting of the galvanized protection is evident					
Direct burial steel poles checked for water/moisture inside pole and corrosion around base of pole					
Direct burial steel poles checked for proper mastic covering inside the pole					
Pull on conduits in hand holes to check for looseness					
Check for all pole electrical access covers in place *					
Check for all external cable conduit to be in good shape, not cracked or missing *					
Check for other visible signs of deterioration? Specify *					
Check any pole climbing equipment for proper attachment, alignment and decay or corrosion					
Check to make sure trees are not encroaching on the pole structures or overhead wires					
Luminaires					
Check for signs of smoky film on lenses, or water damage to luminaires					
Check for broken or missing lenses, replace as needed					
Check for luminaires not operating. Troubleshoot and repair (fuse, lamp, ballast or capacitor for HID)					
Visually inspect ballast/drivers for signs of deterioration					
Do any of the luminaires need realignment (visual and light level testing)					
Insulation covering on wiring should show no signs of wear or cracking					
Ground wire connections must be secure					
Check around ballasts for signs of blackening. (metal halide)					
Check that capacitors aren't bulging. (metal halide)					

Note: Asterisk (*) indicates deficiencies that must be corrected, for safety of participants, prior to hosting playoff events.

Revised 12/2020